

HOW TO SPECIFY**MODEL: 0800
FLAT OVAL ACCESS DOOR****SUGGESTED SPECIFICATION:**

Provide and install as shown on plans and/or schedules and at each fire damper location, duct access doors as manufactured by Nailor Industries, Inc., which meet the following criteria: Access doors shall meet British Standard DW144 Class C for leakage. Manufacturer shall submit leakage data tested to minimum of 8 in. w.g. (2 kPa). Frame shall be of flat oval design, constructed of die-formed 22 ga. (0.85) galvanized steel. Door shall be constructed of die-formed 22 ga. (0.85) galvanized steel and be of double skin construction with 1" (25) insulation fully enclosed within the door panel. Bulb type seal shall be integrally fastened to door for positive seal. Standard of Acceptance shall be Nailor Industries Model 0800.